

THE MAHARASHTRA STATE CO-OP. BANK LTD., MUMBAI

(Incorporating The Vidarbha Co-op. Bank Ltd.,)

Scheduled Bank

Sir Vithaldas Thackersey Smruti Bhavan,
9, Maharashtra Chamber of Commerce Lane,
Fort, Mumbai - 400 001.

Request For Proposal

We invite sealed RFP of "**Rate Contract for Supply & Installation of Exide UPS Batteries for two years**" for our Head office, Mumbai and various Branches & offices in Maharashtra.

Interested contractor should submit duly filled quotation in all respect on or before **13-12-2021** during office hours i.e. 10.15 a. m to 5.00 p.m. (**Mon. to Sat.**) (**Except 2nd & 4th Sat.**) in given format only on company's letter head.

Sealed RFP should be submitted in two separate envelopes i.e. **1) Technical Bid 2) Commercial Bid** & same should be mentioned on the respective envelope.

Technical bid will be opened on **14-12-2021 at 3.00 p.m.** in the presence of bidders & Technically eligible bidders will be called during opening of commercial bid.

Offer should be as per following general Terms & Conditions:-

- 1) Validity of rates should be for Two years from the date of work order.
- 2) Rates should be inclusive of all taxes, transportation, loading & unloading and installation.
- 3) No advance will be paid.
- 4) Delivery and Installation should be as and when required at particular location of the bank in Maharashtra (All offices & Branches in Mumbai, Nagpur, Regional Office at Pune, Nasik, Kolhapur, Aurangabad, Nanded and Nagpur Branches at Dhule, Beed, Solapur, Nanded, Aurangabad, Pune, Nasik, Kolhapur, Amravati, Parabhani, Yeotmal, Osmanabad, Jalna, Wardha, Jalgaon & Akola) immediately after work order.
- 5) Quotation should be inclusive of applicable buyback offer & GST as applicable.

- 6) Right to accept or reject any or all quotations without giving any reasons is reserved with bank.
- 7) Conditional or incomplete RFP will be rejected by the bank.
- 8) Any damage or accident will be the responsibility of supplier.
- 9) The make of the proposed batteries should be of Exide Make.
- 10) Models as per specifications should be mentioned in the commercial Bid.
- 11) Batteries should have been manufactured in India.
- 12) Battery should have been designed for Indian power supply conditions and hence should give minimum following number of cycles.
- 13) The battery should be capable of delivering the following minimum back up time power at an End Module Voltage of 10.5V DC per 12V module.
- 14) Batteries end walls should have reinforcement to avoid bulging during usage of the batteries.
- 15) The assembly line should be automatic with vacuumised acid filling mechanism so that uniform acid fill is achieved.
- 16) Own oxide powder manufacturing facility should be there for the battery manufacturer.
- 17) Own grid and plate making facility should be available.
- 18) The supplier should submit internal test report along with the batteries.
- 19) Principal company should have pan India network.

Address :-

The Joint Manager

The Maharashtra State Co-op. Bank Ltd.,
Estate & Maintenance Dept., 3rd floor,
Sir, Vithaldas Thackersey Memorial Building,
9, Maharashtra Chamber of Commerce Lane,
Fort, Mumbai - 400 001.

Phone No. 022-22800592 / 562

Note:- No Negotiation will be held for Rates, terms & conditions, therefore bidders have to quote their lowest rates.

Following format should be on companies letter head

A) <u>TECHNICAL BID SHOULD CONTAIN :-</u>		
Sr. No.	Particulars	
1.	Name of Company	
2.	Regd. office address	
3.	Phone No. Mobile No.	
4.	Toll free no. of service center	
5.	PAN No. (Pl. attached xerox copy)	
6.	GST No. (Pl. attached xerox copy)	
7.	Client list with work order copies (Pl. attach Separate List with Copy of work order Phone No of Contact Person)	
8.	Income tax returns & Certified Balance Sheet for Last three years (2015-16, 2016-17 & 2017-18)	
9.	Copy of business license	
10.	Necessary Certificate of Production /Supply / dealership	

It is compulsory to fill Annexure "A"

Seal & Signature of Proposer

- **COMMERCIAL BID SHOULD CONTAIN :-**

Sr. No.	Make	Model	Capacity	Type	Rate per battery.	Buyback offer per battery.	warranty period
1			12 V, 26 Ah	SMF			
2			12 V, 42 Ah	SMF			
3			12 V, 65 Ah	SMF			
4			12 V, 75 Ah	SMF			
5			12 V, 100 Ah	SMF			
6			12 V, 120 Ah	SMF			
7			12 V, 150 Ah	SMF			
8			12 V, 200 Ah	SMF			
9			12 V, 7 Ah	SMF			
10			12 V, 40 Ah	TUBULER			
11			12 V,60 Ah	TUBULER			
12			12 V, 75 Ah	TUBULER			
13			12 V, 100 Ah	TUBULER			
14			12 V, 130 Ah	TUBULER			
15			12 V, 160 Ah	TUBULER			
16			12 V,200 Ah	TUBULER			
17			12 V,500 Ah	TUBULER			
18			12 V,40 Ah	TUBULER			
19			12 V,66 Ah	TUBULER			
20			12 V,80 Ah	TUBULER			
21			12 V,100 Ah	TUBULER +			
22			12 V,130Ah	TUBULER +			
23			12 V,150 Ah	TUBULER +			
24			12 V,180 Ah	TUBULER +			

These rates are valid for two year from the date of work order and batteries will be supplied and installed as and when required at particular location of the bank.

Seal & Signature of Proposer